# Town of Trimble Water Quality Report for 2023

#### Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 85 contaminants that may be in drinking water. As listed in the chart, we only detected 18 of these contaminants. We found all of these contaminants at safe levels.

#### What is the source of my water?

Your water, which is ground water, comes from a confined tertiary sand aquifer. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to potential contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving water to this water system. The SWAP Report assesses the susceptibility of untreated water sources to potential contamination. To ensure safe drinking water, all public water systems treat and routinely Water sources have been rated as test their water. reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The Town of Trimble sources rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <a href="https://www.state.tn.gov/environment/article/wr-wq-source-water-assessment">www.state.tn.gov/environment/article/wr-wq-source-water-assessment</a> or you may contact the Water System to obtain copies of specific assessments.

A wellhead protection plan is available for your review by contacting David Norsworthy at the Town of Trimble between 8:00 A.M. to 5:00 P.M. weekdays.

#### Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some stormwater rund contaminants. The presence of contaminants does not discharges, oil a necessarily indicate that water poses a health risk. More farming.

Copyright 2005 TAUD All rights reserved

information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda..

### For more information about your drinking water, please call David Norsworthy at 731-297-3955

#### How can I get involved?

Our Water Board meets on the Second Monday of each month at Trimble City Hall 97 Pierce St. Please feel free to participate in these meetings.

## Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

#### Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm + water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturallyoccurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

#### Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines

means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

#### Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Trimble is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead

#### **Water System Security**

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, tanks, fire hydrants, etc. to 731-297-3955

### Water Quality Data

#### What does this chart mean?

- MCLG Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MCL Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs
  as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents
  a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described
  health effect
- MRDL: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- MRDLG: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- <u>AL</u> Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- Below Detection Level (BDL) laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- Non-Detects (ND) laboratory analysis indicates that the contaminant is not present.
- Parts per million (ppm) or Milligrams per liter (mg/l) explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- Million Fibers per Liter (MFL) million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- IT Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Colitorm	NO	0		2023		0	< 2 positive	Naturally Present in
Bacteria							samples	the environment
Asbestos	NO	NFD	ू दर	2023	MFL	7	7	Decay of asbestos cement water mains; erosion of natural deposits
Copper	NO	90 <sup>th</sup> % = .0942	.02456	2021	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead <sup>4</sup>	NO	90 <sup>th</sup> %	07.25	2021	Ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Fluoride	NO	.400	.360 .440	2023	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Nitrate (as Nitrogen) <sup>5</sup>	NO	2.36	:	2023	ppm	10	10	Runoff from fertilizer use: leaching from septic tanks, sewage: erosion of natural deposits
Sodium	NO	22.3		2023	ppm	NA I	NA	Erosion of natural deposits: used in water treatment
TTHM <sup>6</sup> [Total trihalomethanes]	NO	12.5	05.79	2023	ppb	n/a	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	NO	2.43	0-1.25	2023	ppb	N/A	60	By-product of drinking water disinfection.
Chlorine	No	1.42	1.11.7	2023	ppm	4	4	Water additive used to control microbes.
						1		

#### **Unregulated Contaminants**

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
All Landson								
HAA6Br	NO	4.13	2.15- 4.13	2020	ppb	na	n a	n/a
Bromodichloromethane	NO	0.739		2023	ppb	n a	∍ n√a	n a
Bromoform	NO	0.566		2023	ppb	n/a	n/a	n/a
Chlorodbromethane	NO	0.001		2023	ppb	n/a	n/a	n/a
Chloroform	NO	0.931		2020	ppb	n/a	n/a	n a
Haa9	NO	5.47	2.69- 5.47	2020	ppb	n/a	n/a	n a
bromide	NO	67	62-67	2020	ppb	n/a	n/a	n/a

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations warranted For additional information call the Safe Drinking Water Hotline at 800-426-4791.

#### Health Effects

**Iron:** Iron occurs naturally in our raw water and occasionally accumulates in the distribution system. Iron shows up as "red" or "rusty" water at your tap. Although you do not want to drink water that is not clear, iron is not considered to be a hazard to your health. We test for iron daily and it is usually around 0.2 ppm. The aesthetic limit for iron is 0.3 ppm.

During the most recent round of Lead and Copper testing, 0 out of 10 households sampled contained concentrations exceeding the action level




DWR-PWS-G-01-Consumer Confidence Report-03312020

Consumer Confidence Report Checklist

Appendix C. Sample of Copy and Artwork for Drug Lysposa: Program

#### think before you flush!

This define edicing to an abedia of the feature 4 trights arounding in tell in poer length in pro-ceil Not the form threate day. During a problem of this entering in the common contraction of the about the common of the entering of the feature of the contraction of the contraction of the feature of the contraction of the feature of the contraction of the contraction of the feature of the contraction of the feature of the contraction of the contraction of the feature of the contraction of the feature of the contraction of the contraction of the feature of the f



as the entraction of property of the parties and the extrement

